



TEST REPORT

| | | | |
|----------------|----------------------|--------|---------------------|
| Test Report No | AQC/2627/04/25/53284 | ULR No | TC1079526000007096F |
|----------------|----------------------|--------|---------------------|

| | |
|------------|--|
| Issued To: | St. Elizabeth Convent School 5, Dev Guradia Rd, near Saint Elizabeth convent school, Anand Nagar, Nayta Mundla, Indore, (MP) - 452001 |
|------------|--|

Sample Particulars

| | | | |
|-------------------|----------|--------------------|------------|
| Name of Sample | RO Water | Brand Name | -- |
| Sample Drawn By | Customer | Batch No | -- |
| Sample Quantity | 1 Ltr | Batch Size | -- |
| Packing Condition | Sealed | Date of Receipt | 25/04/2026 |
| Samples Condition | Complies | Date of Testing | 25/04/2026 |
| Date of Mfg | -- | Date of Completion | 01/05/2026 |
| Use By Date | -- | Date of Issue | 01/05/2026 |
| Letter No. | -- | License No. | -- |
| Other Details | RO Water | | |

Test Results

| Sr. No. | Test Parameter | Unit | Specification | Result | Test Method |
|---|------------------------------|------------|-----------------|--------|---------------------------------------|
| Table 1: Chemical & Microbiological Parameters | | | | | |
| 1 | pH value | - | 6.5-8.5 | 6.54 | IS 3025 Part 11 : 2022 |
| 2 | Turbidity | NTU | Max 1.0 | Nil | IS 3025 Part 10 : 2023 |
| 3 | Total Dissolved Solids (TDS) | mg/l | Max 500 | 85.0 | IS 3025 Part 16 : 2023 |
| 4 | Total Hardness | mg/l | Max 200 | 11.45 | IS 3025 Part 21 : 2009 |
| 5 | Total Alkalinity | mg/l | Max 200 | 21.01 | IS 3025 Part 23 : 2023 |
| 6 | Chloride | mg/l | Max 250 | 26.20 | IS 3025 Part 32 : 1988 |
| 7 | Calcium | mg/l | Max 75 | 3.82 | IS 3025 Part 40 : 1991 |
| 8 | Magnesium | mg/l | Max 30.0 | <1.0 | FSSAI Manual Analysis No. 14.022:2024 |
| 9 | E.coli | MPN/100 ml | Shall Be Absent | Absent | IS 1622 : 1981 |
| 10 | Coliform | MPN/100 ml | Shall Be Absent | Absent | IS 1622 : 1981 |

Remark : NA

Specification as per IS 10500:2012(Drinking Water).

-----End of the Report-----

A.Jain, QM
Checked by



R. Maru & Technical Manager

Authorized By

Note: Customer asked for above test only.

Approved by
Laboratory Govt. of India under "AGMARK"

An ISO 9001:2015
Certified

Authorized By
Compliant